



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E001729

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JANUARY 2015**

**OWNER OF OPERATOR (Co.#270)**

AGC Flat Glass North America, Inc. (AGC)  
11175 Cicero Dr, Ste 400  
Alpharetta, GA 30022

**EQUIPMENT LOCATION (Fac.#935)**

AGC Flat Glass North America, Inc. (AGC)  
17300 Silica Dr  
Victorville, CA 92395

**Description:**

DIESEL IC ENGINE, EMERGENCY GENERATOR. consisting of:

One Cummins, Diesel fired internal combustion engine Model No. QSP30G5NR1 and Serial No. 37213937, Turbo Charged, After Cooled, producing 1490 bhp with 12 cylinders at 1800 rpm while consuming a maximum of 69.0 gal/hr. This equipment powers a Cummins Generator Model No. QST30-G5 and Serial No. , rated at 1000 kW.

**EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
PM10	0.13	gm/bhp-hr

**CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
2. Engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 3211

SCC: 20200102

Location/UTM(Km):  
474E/3815N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

AGC Flat Glass North America, Inc.  
(AGC)  
11175 Cicero Dr, Ste 400/Chris Correnti  
Alpharetta, GA 30022

By: **COPY**  
Eldon Heaston  
Air Pollution Control Officer

3. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements.
  
4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
  
5. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 50 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 50 hour per year limit.
  
6. The owner/operator (o/o) shall maintain a operations log for this unit current and on-site, either at the engine location or at a on-site location, for a minimum of five (5) years, and for another year where it can be made available to the District staff within 5 working days from the District's request, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
  - a. Date of each use and duration of each use (in hours);
  - b. Reason for use (testing & maintenance, emergency, required emission testing);
  - c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
  - d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).
  
7. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (Title17 CCR 93115). In the event of conflict between these conditions and the ATCM, the requirements of the ATCM shall govern.