



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E001855

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: DECEMBER 2009**

**OWNER OF OPERATOR (Co.#248)**

Sunray Energy, Inc  
35100 E Santa Fe Road  
Daggett, CA 92327

**EQUIPMENT LOCATION (Fac.#2009)**

Sunray Energy - SEGS II  
35100 E Santa Fe Road  
Daggett, CA 92327

**Description:**

IC ENGINE, EMERGENCY DIESEL GENERATOR consisting of:

One Katolight, fired internal combustion engine Model No. D-600FR24 and Serial No. 37108551, producing 900 bhp with cylinders at 1800 rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

**CONDITIONS:**

1. This equipment shall be operated and maintained in strict accord with manufacturer's and/or supplier's recommendations and/or sound engineering principles.
2. The sulfur content of the diesel fuel used shall not exceed 0.05% by weight. The owner/operator (o/o) shall log all purchases of this fuel including the volume (or weight), date received and the sulfur content. The o/o may use the supplier's sulfur analytical data, but at least annually take a sample of the fuel and submit it for analysis by an independent laboratory/testing firm. The results of said analyses shall be reported to the District upon receipt and logged.
3. This equipment shall be exclusively used as an emergency unit during loss of commercial power. A maintenance procedure shall be established that states how often and for what duration this piece of equipment is to run for preventive maintenance purposes. This procedure is to be kept on site and be available to District personnel on request.
4. An operating log shall be maintained which gives the hours of operation and reason for operating. This log shall be kept on a calendar basis and be kept on site for at least two (2) years and be made available to the District on request.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4911

SCC: 20100102

Location/UTM(Km):  
515E/3838N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Sunray Energy, Inc  
PO Box 338  
Daggett, CA 92327

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

5. This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.