



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E002955

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2004

OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac.#591)

USMC AGCC
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278-8110

Description:

EMERGENCY DIESEL ELECTRICITY GENERATOR (BLDG 1024) consisting of: a Detroit Diesel engine driving a generator. The engine is rated at approximately 670 bhp and drives a Beloit Power Systems, Inc. Generator, which is rated at 500 kW(e), 625 kVA.

CONDITIONS:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 60 minutes of operation per week.
4. The owner/operator (o/o) shall use only diesel fuel or biodiesel B20 fuel whose sulfur concentration is less than or equal to 0.05% on a weight per weight basis or JP-8 fuel.
5. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:
 - a. Date of each test;
 - b. Duration of each test, in minutes;
 - c. Annual operation in terms of total calendar year fuel use (in gallons) or hours;

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 9711

SCC: 99999999

Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

6.A timer shall be installed and maintained on this unit to indicate elapsed engine operating time.