



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E003731

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MARCH 2001

OWNER OF OPERATOR (Co.#1034)

A T & T - San Ramon
311 S. Akard Street, 12th Floor
Dallas, TX 75202

EQUIPMENT LOCATION (Fac.#1356)

A T & T - Sandy Radio Site
10.5 Miles Northwest of
Afton, CA 92338

Description:

EMERGENCY STAND-BY GENSET consisting of: A 218 hp Detroit diesel engine, model No. 6153-N, serial No. 6A172181 and a 115 kW Delco generator, model No. E5206, type alternator.

CONDITIONS:

1. This engine shall be operated when utility power (line power) is not available due to a power outage and, for testing, no more than one hour in any one day and in any one week.
2. The fuel used to operate this engine shall not contain more than 0.05% sulfur on a weight to weight basis.
3. The owner/operator (o/o) shall require analytical results relating to the sulfur content of the fuel delivered by their supplier. The o/o shall not accept delivery whenever the sulfur concentration exceeds 0.05% by weight.
4. The o/o shall maintain copies of the delivered fuel test results on-site and provide them to District personnel upon request.
5. The o/o shall log the starting and stopping times, the "hour meter" reading, and date each time the engine is operated. This log shall be maintained on-site for a minimum of two years and be made available to District personnel upon request.
6. The o/o shall comply with all applicable rules and regulations of the District.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4813

SCC: 9999999

Location/UTM(Km):
519E/3865N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

A T & T - San Ramon
311 S. Akard Street, 12th Floor
Dallas, TX 75202

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

7. This engine shall be operated and maintained in strict accord with the manufacturer's recommendations and/or sound engineering principles.