MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E004018

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2001

OWNER OF OPERATOR (Co.#69)

Southern California Edison
P.O. Box 5085
Rosemead, CA 91770

EQUIPMENT LOCATION (Fac.#96)

SCE - Solar II
East Santa Fe Road
Daggett, CA 92327

Description:
EMERGENCY FIREPUMP consisting of: Cummings Diesel, model No. V378F2 and serial No. 20212667, rated at 125 bhp. The unit uses diesel fuel at approximately 7.4 gallons per hour.

CONDITIONS:

1. The owner/operator (o/o) shall log all starting and stopping times of all uses of this unit, to the nearest minute, date, and delivery date of fuel.

2. The o/o shall comply with all applicable rules and regulations of the District. Applicable rules include, but are not limited to Regulation IV.

3. The o/o is limited to using diesel fuel whose sulfur concentration exceeds 0.05% on a weight per weight basis.

4. The o/o shall not use any fuel in this unit other than diesel without the written prior permission of the District. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, a sample of the fuel shall be taken and submitted for analysis by an independent laboratory/testing firm. The results of said analysis, by ASTM methods D 4294 or D 2622-82 (or equivalent), shall be logged.

Fee Schedule: 7 (g)	Rating: 1 device	SIC: 9711	SCC: 99999999	Location/UTM(Km): 591E/3856N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison
P.O. Box 5085

Rosemead, CA 91770

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

5. The o/o shall maintain the logs current, on-site for a minimum of two years and provided to District personnel on request.

6. This unit shall only be used for emergency power when commercially available power is interrupted. The unit may be operated weekly as part of a testing program which does not exceed 4 h/month.

7. This unit shall not be operated more than 1000 h yearly without prior written approval of the District APCO.