



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E004064

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 1998

OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac.#591)

USMC AGCC
Box 788110, Bldg. 1451
Twentynine Palms, CA 922788110

Description:

EMERGENCY ELECTRICAL GENERATOR consisting of:

One CASE, Diesel fired internal combustion engine Model No. 100 and Serial No. 2524983, producing 144 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 144 gph. This equipment powers a Model No. and Serial No., rated at.

CONDITIONS:

1. The owner/operator (o/o) shall log all starting and stopping times of the test periods of this generator, to the nearest hour; the date; and the delivery of fuel.
2. The o/o shall comply with all applicable rules and regulations of the District.
3. The o/o shall not use diesel fuel whose sulfur concentration is less than or equal to .05% on w/w.
4. The o/o shall not use any fuel in this generator other than diesel without the written prior permission of the District. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the fuel and submit it for analysis by an independent laboratory. The results of said analyses, by ASTM method D 2622-82, shall be logged.
5. The o/o shall maintain the logs current, on-site for a minimum of 2 years and provided to District personnel on request.
6. This unit shall be used only for emergency power when commercially available power is interrupted. The unit may be operated

Fee Schedule: 7 (c) Rating: 1 device SIC: 9711 SCC: 20100102 Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418
Twentynine Palms, CA 92278-8110

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

weekly as part of a testing program which does not exceed 60 minutes per week.

7. This unit shall not be operated more than 1000 hours in a calendar year without prior written approval of the District APCO.