



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

E004309

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: SEPTEMBER 2026**

**OWNER OF OPERATOR (Co.#1732)**

Helendale Community Services District  
26540 Vista Road Suite B  
Helendale, CA 92342

**EQUIPMENT LOCATION (Fac.#1418)**

Helendale Community Services District  
28685 Helendale Road  
Helendale, CA 92342

**Description:**

NATURAL GAS IC ENGINE, EMERGENCY GENERATOR consisting of: a Minneapolis Moline natural gas fired 6 cylinder engine. The engine is rated at 165 bhp at 1800 rpm and the model number is HD 800A-6A and serial number is 34902178. The generator driven by the engine is by Electro Motion, their model 440 FDC and serial number BB795091 rated at 125 kW @ 175 amp. Engine is estimated to consume 1104 scf/hr of natural gas. Equipment elevation is 2431 feet above sea level.

One Minneapolis Moline, NG fired internal combustion engine Model No. HD800A-6A and Serial No. 34902178, producing 165 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 1104 scf/hr. This equipment powers a Electro Motion Generator Model No. 440 FDC and Serial No. BB795091, rated at 125 kW.

**CONDITIONS:**

1. This stationary, spark-ignited, internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[40 CFR 60, Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines, Subpart 60.4243; District Rule 1302]

2. This unit shall be fired on PUC-Regulated Pipeline Quality natural gas only.  
[40 CFR 60.4243]

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4952

SCC: 20200253

Location/UTM(Km):  
470E/3848N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Helendale Community Services District  
P.O. Box 359  
Helendale, CA 92342-0359

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

3. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.  
[District Rule 1302]

4. This unit shall be operated no more than 100 hours per year for testing and maintenance.  
[40 CFR 60.4243]

5. The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of two (2) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption in standard cubic feet or total hours; and
- d. Maintenance and Repair actions on the engine.

[40 CFR 60.4245]

6. This engine shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[District Rule 1302]

7. This engine may operate in response to notification of impending involuntary rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[District Rule 1302]

8. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]