



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E004310

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: SEPTEMBER 2007**

### **OWNER OF OPERATOR (Co.#1732)**

Helendale Community Services District  
26540 Vista Road Suite B  
Helendale, CA 92342

### **EQUIPMENT LOCATION (Fac.#1418)**

Helendale Community Services District  
28685 Helendale Road  
Helendale, CA 92342

#### **Description:**

NATURAL GAS IC ENGINE, EMERGENCY GENERATOR consisting of: an International Harvester natural gas fired 8 cylinder engine. The engine is rated at 101 bhp at 1800 rpm. The model number of the engine is KOC UV54911A and the serial number is V549LPG133923. The engine drives a generator by Kohler, their model 85R72 and serial number 401797 and is rated at 75 kW @ 113 amp.

#### **CONDITIONS:**

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 60 minutes of operation per week.
4. The owner/operator (o/o) shall use only pipeline regulated natural gas for fuel.
5. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:
  - a. Date of each test;
  - b. Duration of each test, in minutes;

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4952

SCC: 20100202

Location/UTM(Km): 470E/3848N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Helendale Community Services District  
P.O. Box 359  
Helendale, CA 92342-0359

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

c. Annual operation in terms of total calendar year fuel use (in gallons) or hours;