



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E005097

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JANUARY 2025**

**OWNER OF OPERATOR (Co.#2278)**

Frontier California Inc.  
280 S. Locust Street  
Pomona, CA 91766

**EQUIPMENT LOCATION (Fac.#1782)**

Frontier - La Paz  
15168 La Paz  
Victorville, CA 92392

**Description:**

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: An uncertified engine, manufactured in TBD (installed prior to 1997) with no exhaust after-treatment device installed. Emission factors from CARB OFFROAD Model (>751 hp, model yr 1998)

One Detroit, Diesel fired internal combustion engine Model No. 9123-7426 and Serial No. 12E0010990, Turbo Charged, After Cooled, producing 1750 bhp with 16 cylinders at 1800 rpm while consuming a maximum of 87 gal/hr. This equipment powers a Detroit Diesel Generator Model No. 1250DS and Serial No. 395302, rated at 1250 kW(e).

**EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	2.7	gm/bhp-hr
NOx	8.17	gm/bhp-hr
PM10	0.38	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.68	gm/bhp-hr

**CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 1302]

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4813

SCC: 20100102

Location/UTM(Km):  
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Frontier California Inc.  
280 S. Locust Street  
Pomona, CA 91766

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

2. A non-resettable hour meter with a minimum display capability of 9,999 hours shall be installed and maintained on this unit to indicate elapsed engine operating time.

[Title 17 CCR 93115.10(d)]

3. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,

b. A cetane index or aromatic content, as follows:

1. A minimum cetane index of 40; or,

2. A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a) and 40 CFR 80.510(b)]

Note: Use of CARB certified ULSD fuel satisfies the above requirements.

4. This unit shall be limited to emergency use only, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 20 hour per year limit.

[17 CCR 93115.6(b)]

5. The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

a. Date of each use and duration of each use (in hours per hour meter);

b. Reason for use (testing & maintenance, emergency, required emission testing);

c. Calendar year operation in terms of fuel consumption (in gallons or total hours);

d. Records of all required maintenance and inspections; and,

e. Fuel sulfur concentration (the owner/operator may use the supplier's certification of sulfur content if it is maintained as part of this log).

[17 CCR 93115.10(f)]

6. The owner/operator shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

[District Rule 1302(c)(2)]

7. This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(2)]

8. This engine is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines Title 17 CCR 93115.

[District Rule 204]

9. As authorized in 40 CFR 63.6585(f), this area HAP source engine is currently exempt from the requirements of 40 CFR 63, subpart ZZZZ - the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (the RICE NESHAP).

Upon loss of this exemption, immediate compliance with 40 CFR 63, Subpart ZZZZ is required. Additionally, this existing commercial emergency stationary engine shall not operate for non-emergency use as part of any financial arrangement with any other entity.

[40 CFR 63.6585(f), 40 CFR 63.6640(f), and 40 CFR 63.6675]

10. This engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(b)]

11. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]