



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

E007792

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: FEBRUARY 2027

OWNER OF OPERATOR (Co. #2349)

MP Mine Operations LLC
67750 Bailey Road
Mountain Pass, CA 92366

EQUIPMENT LOCATION (Fac. #364)

Mountain Pass Mine
67750 Bailey Road
Mountain Pass, CA 92366

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: Year of Manufacture: Unknown

One Caterpillar, Diesel fired internal combustion engine Model No. 3512 DITA and Serial No. 8RM00698, producing 1764 bhp with 12 cylinders at 1800 rpm while consuming a maximum of 90.0 gal/hr. This equipment powers a Generator Model No. and Serial No. , rated at 1252 Kw.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1303]

[60 CFR 60.4211]

2. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

- a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
- b. A cetane index or aromatic content, as follows:
 - (i) A minimum cetane index of 40; or,

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 1099

SCC: 20100102

Location/UTM(Km):
634E/3926N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MP Mine Operations LLC
1700 S. Pavilion Center Drive, 8th Floor
Las Vegas, NV 89135

By: **COPY**
Brad Poiriez
Executive Director

(ii) A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a), 40 CFR 80.510(b), and 40 CFR 60.4207(b)]

Note: Use of CARB certified ULSD fuel satisfies these requirements.

3. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.

[17 CCR 93115.10(d)]

4. This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power and/or power generated by combustion turbines under permits B011111 and B011184 has been interrupted. In addition, this engine shall be operated no more than 8 hours per day and 20 hours per year for testing and maintenance. Emergency use includes planned and unplanned outages of alternative energy supply from combustion turbines under permits B011111 and B011184 when the facility has no other source of power available. Such emergency use shall not exceed 200 hours total per year. The owner/operator must notify the District prior to the use of this emergency generator during a "planned outage" emergency. Notifications must be sent to reporting@mdaqmd.ca.gov and include the permit number(s) and the dates of the outage.

[District Rule 301 (E)(7)(g)]

[17 CCR 93115.6(a)(3)(A)(1)(c)]

5. The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

a. Date(s) of each use and hours of operation;

b. Reason for use (regular testing & maintenance, emergency, etc.);

c. Monthly and rolling 12 month period operation in terms of fuel consumption (in gallons) and/or total hours (both emergency and non-emergency use, classified as described in b. above);

d. Fuel sulfur concentration as required by condition 5 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,

e. Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

6. This unit shall not be used to provide power during an ordered power outage initiated under an Interruptible Service Contract (ISC) or similar arrangement(s).

[17 CCR 93115.6(c)(1)(C)]

7. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (Title 17 CCR 93115). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.

8. Actual emissions from this facility shall be less than the following:

a. 42 tons per year of NO_x [Rule 1303(B)]

b. 46 tons per year of PM₁₀ [Rule 1303(B)]

c. 25 tons per year of VOC

d. 25 tons per year of SO_x

e. 100 tons per year of CO, calculated on a rolling twelve-month basis

f. 10 tons per year for any single HAP and 25 tons per year for any combination of HAPs calculated on a rolling twelve-month basis.

HAPs are defined in 40 CFR 61.01 and are the chemical compounds listed in section 112(b) of the Clean Air Act (Act). Compliance with the annual emission limits shall be demonstrated via 12 month rolling sum for CO and HAP via annual emission inventory reports for all criteria pollutants and HAP.

[District Rule 1303]

9. This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

10. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]