



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

E009742

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: MAY 2026

OWNER OF OPERATOR (Co.#2239)

CalPortland Company
19409 National Trails Hwy
Oro Grande, CA 92368

EQUIPMENT LOCATION (Fac.#3)

CalPortland Oro Grande
19409 National Trails Hwy
Oro Grande, CA 92368

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A diesel engine, manufactured in 2006.

One Cummins, Diesel fired internal combustion engine Model No. QSK60-GE NR2 and Serial No. 75779-210 , Turbo Charged, After Cooled, producing 2922 bhp with 16 cylinders at 1800 rpm while consuming a maximum of 138.0 gal/hr. This equipment powers a Cummins Generator Model No. 2000DQKAB and Serial No. H070089473, rated at 2000 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	2.61	gm/bhp-hr
NOx	4.53	gm/bhp-hr
NOx+NMHC	4.77	gm/bhp-hr
PM10	0.15	gm/bhp-hr
SOx	0.10	gm/bhp-hr
VOC	0.24	gm/bhp-hr

CONDITIONS:

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 3241

SCC: 20100102

Location/UTM(Km):
469E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CalPortland Company
Attn: Catalina Elias

Oro Grande, CA 92368

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. This equipment must be installed, operated, and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment must be operated in accordance with all data and specifications submitted with the application for this permit.
[District Rule 204; 40 CFR 60.4206, 60.4211(a), and 60.4211(b)]

2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
[17 CCR 93115.10(d); 40 CFR 60.4209(a)]

3. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:
 - (a) Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
 - (b) A cetane index or aromatic content, as follows:
 - (i) A minimum cetane index of 40; or,
 - (ii) A maximum aromatic content of 35 volume percent.Note: Use of CARB certified ULSD fuel satisfies these requirements.
[17 CCR 93115(a); 40 CFR 80.510(b), 60.4207(b); District Rule 431]

4. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 30 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 30 hour per year limit.
[Title 17 CCR 93115.6(b)(3)(A)1.b; 40 CFR 60.4211(f)]

5. The owner/operator (o/o) shall maintain an operations log for this unit current and onsite, either at the engine location or at an on-site location, for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
 - (a) Date of each use and duration of each use (in hours);
 - (b) Reason for use (testing & maintenance, emergency, non-emergency, required emission testing);
 - (c) Calendar year operation in terms of fuel consumption (in gallons) and total hours;
 - (d) Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log);
 - (e) Occurrence and duration of any malfunction(s) of the equipment; and,
 - (f) All required maintenance performed on the equipment.[District Rule 1302; 17 CCR 93115.10(f); 40 CFR 63.6655(a)]

6. Engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.
[Title 17 CCR 93115.6]

7. This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.
[17 CCR 93115.6(c)(1)(C)]

8. Diesel particulate matter will be controlled by the installation of CombiKat CBS Particulate Trap (diesel particulate filter) (CARB certified greater than or equal to 85% reduction efficiency), certified by CARB Executive Order G-02-003.
[District Rule 204]

9. Pursuant to 40 CFR 63 Subpart ZZZZ section 63.6640(f), this stationary emergency engine may be operated up to 50 hours per year for limited non-emergency purposes. The 50 hours per year for non-emergency situations cannot be used for peak shaving or demand response, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity. If the engine operates for non-emergency purposes contrary to these requirements, the engine will no longer be considered an emergency engine and must meet all requirements for non-emergency engines.
[40 CFR 63.6640(f)]