



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E009902

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2009

OWNER OF OPERATOR (Co.#1597)

Mervyn's LLC
22301 Foothill Blvd, MS - 4025
Hayward, CA 94541

EQUIPMENT LOCATION (Fac.#2949)

Mervyn's Store #331
19131 Bear Valley Road
Apple Valley, CA 92308

Description:

NATURAL GAS IC ENGINE, EMERGENCY GENERATOR consisting of: Yr of Mfg 2006-2007

One Generac, NG fired internal combustion engine Model No. QT-080A and Serial No. tbd, Other, Other, producing 138 bhp with 8 cylinders at 2650 rpm while consuming a maximum of 1.0 scf/hr. This equipment powers a Generac Generator Model No. QT-080 and Serial No. TBD, rated at 80 kW.

CONDITIONS:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. This unit shall only be fired on natural gas or propane.
4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
5. The owner/operator (o/o) shall maintain a operations log for this unit current and on-site, either at the engine location or at a on-site location, for a minimum of two (2) years, and for another year where it can be made available to the District staff within 5 working days

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 5311

SCC: 20300201

Location/UTM(Km):
482E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Mervyn's LLC
22301 Foothill Blvd, MS - 4025
Hayward, CA 94541

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

from the District's request, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in scf or equivalent) and total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

6. This unit shall be operated no more than 100 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 100 hour per year limit.