



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

E010422

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co. #46)

Victorville, City of
14343 Civic Drive
Victorville, CA 92392-2399

EQUIPMENT LOCATION (Fac. #1656)

Victorville - City Offices
14343 Civic Drive
Victorville, CA 92392

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A certified tier 3 engine, USEPA Family 7JDXL06.8105, manufactured in 2007 with no exhaust after-treatment device installed.

One John Deere, Diesel fired internal combustion engine Model No. 4045HF285I and Serial No. 2166721, Direct Injected, Inter Cooled, Turbo Charged, producing 158 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 8.0 gal/hr. This equipment powers a Detroit Diesel Generator Model No. 457 and Serial No. 2166721, rated at 81 kW(e).

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	1.34	gm/bhp-hr
NOx	2.77	gm/bhp-hr
PM10	0.13	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.09	gm/bhp-hr

CONDITIONS:

1. This certified, stationary, compression-ignited, internal combustion engine and control devices shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all

Fee Schedule: 7 (g) Rating: 1 device SIC: 9131 SCC: 20200102 Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of
Public Works - Fleet Division

Victorville, CA 92392-2399

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

data and specifications submitted with the application for this permit.
[40 CFR 60.4211(a)]

2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.
[17 CCR 93115.10(d) and 40 CFR 60.4209(a)]

3.This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

- a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, equal to a weight per weight basis; and,
- b. A cetane index or aromatic content, as follows:
 - (i) A minimum cetane index of 40; or,
 - (ii) A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(b) and 40 CFR 60.4207(b)]

4.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);
- c. Monthly and calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration and cetane index, as required by condition 3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,
- e. Maintenance performed on this equipment [40 CFR 60.4214(a)(2)(ii)].

[17 CCR 93115.10(f) and 40 CFR 60.4212(b)]

5.This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power has been interrupted. In addition, this engine shall be operated no more than 50 hours per year for testing and maintenance.
[17 CCR 93115.6(a)(3)(1)(c)]

6.This equipment may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

7.This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(1)(C)]

8.This equipment is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS).

9.The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request.