



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

E010772

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: NOVEMBER 2025**

#### OWNER OF OPERATOR (Co. #86)

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA 92278-8110

#### EQUIPMENT LOCATION (Fac. #3247)

USMC AGCC - USMC Facilities  
Box 788110, Bldg. 1451  
Twentynine Palms, CA 92278

#### Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR (BLDG 1118) consisting of: Model Year 2007, Tier 3, EPA Family 7SZXL05.21XB. GenSet Model no. DCA-125SSIU, Serial No. 7510028.

Onelsuzu, Diesel fired internal combustion engine Model No. B14HK1XYGD01 and Serial No. 4HK1K1-424387, Direct Injected, Inter Cooled, Turbo Charged, producing 152 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 7.0 gal/hr. This equipment powers a MQ Power Generator Model No. DB-1381I and Serial No. 688504, rated at 100 KW.

#### EMISSIONS RATES

| Emission Type | Est. Max Load | Unit      |
|---------------|---------------|-----------|
| CO            | 1.0           | gm/bhp-hr |
| NOx           | 2.7           | gm/bhp-hr |
| PM10          | 0.05          | gm/bhp-hr |

#### CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

2. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 9711      SCC: 20100102      Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
  
Twentynine Palms, CA 92278-8110

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

weight per weight basis per CARB Diesel or equivalent requirements.

3.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

4.The o/o shall maintain a operations log for this unit current and on-site, either at the engine location or at a on-site location, for a minimum of two (2) years, and for another year where it can be made available to the District staff within 5 working days from the District's request, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

5.This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 50 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 50 hour per year limit.

6.Engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

7.This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

8.This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (Title 17 CCR 93115). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.