



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E012099

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2026

OWNER OF OPERATOR (Co.#2595)

Desert Physician Management, LLC
19111 Town Center Drive
Apple Valley, CA 92308

EQUIPMENT LOCATION (Fac.#3526)

Desert Physicians Management, LLC
19111 Town Center Drive
Apple Valley, CA 92308

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A certified Tier 2 Diesel engine, EPA Family FCEXL015.AAJ, manufactured in 2014 with no exhaust after-treatment device installed. Equipment includes an integral 1700 gallon diesel tank. Stack is 6 inches in diameter, and 14 feet high. Equipment Elevation is 2836 feet above sea level.

One Cummins, Diesel fired internal combustion engine Model No. QSX15-G9 and Serial No. 79885996, Turbo Charged, producing 563 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 30.1 gal/hr. This equipment powers a Cummins Generator Model No. 450DFEJ and Serial No. K150893475, rated at 450 kW(e).

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.4	gm/bhp-hr
NOx	3.7	gm/bhp-hr
PM10	0.08	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.195	gm/bhp-hr

CONDITIONS:

1. This certified stationary compression-ignited internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 6061

SCC: 20100102

Location/UTM(Km):
482E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Desert Physician Management, LLC
19111 Town Center Drive
Apple Valley, CA 92308

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

specifications submitted with the application for this permit.
[40 CFR 60.4211(a)]

2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.

[17 CCR 93115.10(d)]

3. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,

b. A cetane index or aromatic content, as follows:

(i) A minimum cetane index of 40; or,

(ii) A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a) and 40 CFR 60.4207(b)]

Note: Use of CARB certified ULSD fuel satisfies the requirements of subparagraph 3.b above.

4. The owner/operator shall maintain an operations log for this engine current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

a. Date of each use and duration of each use (in hours);

b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);

c. Monthly and calendar year operation in terms of fuel consumption (in gallons) and/or total hours;

d. Fuel sulfur concentration as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,

e. Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

5. This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

6. This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(1)(C)]

7. This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS).

[40 CFR 60, Subpart IIII, Title 17 CCR 93115, District Rule 1302]

8. This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power has been interrupted. In addition, this engine shall be operated no more than 50 hours per year for testing and maintenance and shall not operate more than 100 hours for non-emergency use in any rolling twelve (12) month period.

[17 CCR 93115.6(a)(3)(1)(c), District Rule 1160]

9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]