



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

## PERMIT TO OPERATE

E012424

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

### EXPIRES LAST DAY OF: NOVEMBER 2024

#### OWNER OF OPERATOR (Co. #86)

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA 92278-8110

#### EQUIPMENT LOCATION (Fac. #3252)

USMC AGCC - USMC Utilities  
Box 788110, Bldg. 1451  
Twentynine Palms, CA 92278

#### Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR, OCOTILLO LIFT STATION consisting of: Year of Mfg. 2014, USEPA Tier 4, EPA Engine Family ESZXL02.2PXB, CARB EO UR 006-0385, MultiQuip GenSet Model DCA45SSIU4F and Serial No. 7250731.

Onelsuzu, Diesel fired internal combustion engine Model No. 4LE2X and Serial No. 4LE2XDPBB-01, After Cooled, Direct Injected, Diesel Oxidation Catalyst, Electronic Control Module, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Turbo Charged, producing 65.7 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 2.93 gal/hr. This equipment powers a Brushless AC Generator Model No. DH-04801(T4) and Serial No. V-027035, rated at 40 kW.

#### EMISSIONS RATES

| Emission Type | Est. Max Load | Unit      |
|---------------|---------------|-----------|
| CO            | 0.01          | gm/bhp-hr |
| NOx           | 2.261         | gm/bhp-hr |
| NOx+NMHC      | 2.38          | gm/bhp-hr |
| PM10          | 0.014         | gm/bhp-hr |
| SOx           | 0.004         | gm/bhp-hr |
| VOC           | 0.12          | gm/bhp-hr |

#### CONDITIONS:

1. This certified Tier 4 stationary engine shall be installed, operated and maintained according to the manufacturer's emission-related

Fee Schedule: 7 (a)      Rating: 0 device      SIC: 9711      SCC: 20100102      Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
  
Twentynine Palms, CA 92278-8110

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

written instructions. Further, the owner/operator shall change only those emission-related settings that are permitted by the manufacturer. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[40 CFR Part 60 Subparts 60.4205, and 60.4211]

2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.  
[17 CCR 93115]

3.This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15ppm) on a weight per weight basis per CARB Diesel or equivalent requirements.

[17 CCR 93115; 60.4207(b); District Rule 431]

4.This unit shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 50 hours per year for testing and maintenance.

[17 CCR 93115; 40 CFR 60.4211(f)]

5.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

a. Date of each use and duration of each use (in hours);

b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);

c. Monthly and calendar year operation in terms of fuel consumption (in gallons) and/or total hours [17 CCR 93115]; and,

d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log) [17 CCR 93115].

6.This engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

7.This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115]

8.This unit shall be operated and maintained so as to meet the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (17 CCR Section 93115) and 40 CFR Part 60, Subpart IIII (NSPS).

9.In each calendar year, the actual emissions of this facility shall be less than 20 tons NO<sub>x</sub>, 20 tons VOC, and 12 tons PM<sub>10</sub> (SM80 Emission Rate). The owner/operator shall demonstrate compliance with this limit on an annual basis through the submission of the Comprehensive Emission Inventory Report (CEIR) to the District. Copies of the CEIR(s) must be kept and maintained on-site for at least five years and presented to District personnel upon request.

[District Rule 221; District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]