



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

E013479

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: JUNE 2026**

#### OWNER OF OPERATOR (Co. #1630)

Golden State Water Company  
630 East Foothill Blvd.  
San Dimas, CA 91773

#### EQUIPMENT LOCATION (Fac. #3917)

Golden State Water Co - Bella Vista  
9345 Bella Vista Ave.  
Morongo Valley, CA 92256

#### Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A Certified Tier 3 diesel engine, US EPA Family KCEXL0275AAK, manufactured in 2019 with no exhaust after-treatment device installed. Exhaust flow is approximately 609 acfm at 622 degrees Fahrenheit through a 7.7 foot high by 4 inch diameter stack.

OneCummins, Inc., Diesel fired internal combustion engine Model No. QSB5-G13 and Serial No. 74500364, Charge Air Cooler, Turbo Charged, producing 173 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 5.30 gal/hr. This equipment powers a Cummins, Inc. Generator Model No. C50D60C and Serial No. F190585759, rated at 60 kW.

#### EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.660	gm/bhp-hr
NOx	2.65	gm/bhp-hr
NOx+NMHC	2.79	gm/bhp-hr
PM10	0.10	gm/bhp-hr
PM2.5	0.099	gm/bhp-hr
SOx	0.003	gm/bhp-hr
VOC	0.1395	gm/bhp-hr

#### CONDITIONS:

Fee Schedule: 7 (g)      Rating: 173 device      SIC: 4941      SCC: 20100102      Location/UTM(Km): 543E/3771N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Golden State Water Company  
630 East Foothill Blvd.  
San Dimas, CA 91773

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

- 1.This certified Tier 3 stationary compression-ignited internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[40 CFR 60.4211(a)]
- 2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.  
[17 CCR 93115.10(d)]
- 3.This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:
- a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
  - b. A cetane index or aromatic content, as follows:
    - (i) A minimum cetane index of 40; or,
    - (ii) A maximum aromatic content of 35 volume percent.
- [17 CCR 93115.5(a), 40 CFR 80.510(c), and 40 CFR 60.4207(b)]  
Note: Use of CARB certified ULSD fuel satisfies these requirements.
- 4.The owner/operator shall maintain an operations log for this engine current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:
- a. Date of each use and duration of each use (in hours);
  - b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);
  - c. Monthly and rolling 12 month period operation in terms of fuel consumption (in gallons) or total hours;
  - d. Fuel sulfur concentration as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,
  - e. Maintenance performed on this equipment.
- [17 CCR 93115.10(f)]
- 5.This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.  
[17 CCR 93115.6(a)(2)]
- 6.This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.  
[17 CCR 93115.6(c)(1)(C)]
- 7.This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power has been interrupted. In addition, this engine shall be operated no more than 50 hours per year for testing and maintenance.  
[17 CCR 93115.6(a)(3)(1)(c); District Rule 1320 (hour limiting)]
- 8.This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.  
[District Rule 1302]
- 9.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.  
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]