



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

E013768

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2025

OWNER OF OPERATOR (Co.#199)

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

EQUIPMENT LOCATION (Fac.#3995)

SBCo - Paxton Mountain
58399 Serin Drive
Yucca Valley, CA 92284

Description:

LPG IC ENGINE, EMERGENCY GENERATOR consisting of: A propane/LPG fueled emergency generator manufactured 2019. Exhaust flow is 679.5 acfm at 1250 degrees Fahrenheit.

OneFord, LPG fired internal combustion engine Model No. 6.8GLPN-70 and Serial No. E172A3007192110047, Three-Way Catalyst (also NSCR), Electronic Control Module, producing 112 bhp with 10 cylinders at 1800 rpm while consuming a maximum of 1.38 scf/hr. This equipment powers a Generac Generator Model No. SG0070AG036.8V18HPNNC and Serial No. 3005149721, rated at 70 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.27	gm/bhp-hr
NOx	1.08	gm/bhp-hr
PM10	0.00	gm/bhp-hr
PM2.5	0.00	gm/bhp-hr
SOx	0.00	gm/bhp-hr
VOC	0.14	gm/bhp-hr

CONDITIONS:

Fee Schedule: 7 (g) Rating: 1 device SIC: 9199 SCC: 20201001 Location/UTM(Km): 556E/3779N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

1.This certified, stationary, spark-ignited, internal combustion engine and control device shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[40 CFR 60.4243(a)(1), Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines]

2.This unit shall be fired on Liquefied Petroleum Gas (LPG) fuel only.

[District Rule 1302(C)(2)(a)]

3.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[District Rule 1302(C)(2)(a)]

4.The air-to-fuel ratio controller shall be used in conjunction with the operation of the three-way catalyst, and shall be maintained and operated appropriately to ensure proper operation of the engine and control device to minimize emissions at all times.

[40 CFR 60.4243(g), Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines]

5.This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 100 hours per year for testing and maintenance, excluding compliance source testing.

[40 CFR 60.4243(d), Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines, Rule 1320]

6.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of two (2) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

a. Date of each use and duration of each use (in hours);

b. Reason for use (testing & maintenance, emergency, required emission testing);

c. Calendar year operation in terms of fuel consumption (in standard cubic feet or gallons) or total hours; and,

d. Records of all maintenance and repair actions performed on the engine, the AFRC, and the three-way catalyst.

[40 CFR 60.4245, Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines]

7.Engine may operate in response to notification of impending involuntary rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

8.This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[40 CFR 60.4243(d), Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines]

9.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]