



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

E013900

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co. #1654)

New Cingular Wireless PCS, LLC
311 S. Akard Street, 12th Floor
Dallas, TX 75202

EQUIPMENT LOCATION (Fac. #4028)

AT & T Mobility - Ibex Pass
SE of Hwy 127 & County Line
Baker, CA 92364

Description:

LPG IC ENGINE, EMERGENCY GENERATOR consisting of: A certified LPG (Propane) fueled engine, USEPA Family LGNxB04.52L2, manufactured in 2020 with factory installed emission control devices. Exhaust flow is approximately 564 acfm at 900 degrees Fahrenheit through an 8 foot tall by 4 inch diameter vertical stack.

OneGenerac, LPG fired internal combustion engine Model No. 4.5L and Serial No. TBD, Air-To-Fuel Ratio Controller, Electronic Control Module, Spark-Ignited, Three-Way Catalyst (also NSCR), producing 76 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 6.2 gal/hr. This equipment powers a Generac Generator Model No. SG035 and Serial No. 3006055116, rated at 35 kW(e).

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.13	gm/bhp-hr
NOx	0.17	gm/bhp-hr
PM10	0.01	gm/bhp-hr
PM2.5	0.01	gm/bhp-hr
SOx	0.0404	gm/bhp-hr
VOC	0.02	gm/bhp-hr

CONDITIONS:

1. This certified, stationary, spark-ignited, internal combustion engine and its associated 3-way catalytic converter and air/fuel ratio

Fee Schedule: 7 (g) Rating: 1 device SIC: 4813 SCC: 20301001 Location/UTM(Km): 560E/3849N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

New Cingular Wireless PCS, LLC
ATTN: EH&S

Dallas, TX 75202

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

controller shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[40 CFR 60, Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines, subpart 60.4243; District Rule 1302]

2.This unit shall be fired on Commercial Grade Liquified Petroleum Gas (LPG) fuel only.

[40 CFR 60.4243]

3.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[40 CFR 60.4237]

4.This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power has been interrupted. In addition, this engine shall be operated no more than 100 hours per year for testing and maintenance.

[40 CFR 60.4243]

5.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in standard cubic feet or gallons) or total hours;
- d. Maintenance conducted on the engine; and
- e. Maintenance and repairs conducted on the Air-to-Fuel Ratio Controller and the Three-Way Catalyst.

[40 CFR 60.4243, 40 CFR 60.4245]

6.The Air-to-Fuel Ratio Controller shall be used in conjunction with the operation of the three-way catalyst, and shall be maintained and operated appropriately to ensure proper operation of the engine and control device to minimize emissions at all times.

[40 CFR 60.4243]

7.This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[District Rule 1302]

8.This engine may operate in response to notifications of impending involuntary rotating outages if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[District Rule 1302]

9.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607, 44341 44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]