



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E014840

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#87)

Commanding Officer, MCLB Barstow, CA
Box 110570 Bldg 196 Attn: Air Program Manager
Barstow, CA 92311-5050

EQUIPMENT LOCATION (Fac.#1177)

USMC MCLB - Nebo Annex
USMC Logistics Base
Barstow, CA 923115013

Description:

DIESEL IC ENGINE, PORTABLE* EMERGENCY GENERATOR consisting of: A Certified Tier 4 Final diesel engine, USEPA family PSZXL05.2RXB, manufactured in 2023. Exhaust flow approximately 512 acfm, at 658 degrees Fahrenheit through a 8.43 foot high by TBD inch diameter exhaust stack. Equipment is located at an elevation of 2138 feet above MSL. *Please note, this equipment may be operated at various locations, however emissions comply with the stationary requirements of 17 CCR 93115 and 40 CFR 60, Subpart IIII. While the engine MAY be used at various locations, the engine is not required to move from its footprint on an annual basis.

One Isuzu, Diesel fired internal combustion engine Model No. BR-4HK1X and Serial No. 4HK1-863524-23FH0M, Direct Injected, Turbo Charged, Selective Catalytic Reduction, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Diesel Oxidation Catalyst, Electronic Control Module, Compression-Ignited, Selective Catalytic Reduction, Charge Air Cooler, producing 152 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 8.40 gal/hr. This equipment powers a MQ Power Generator Model No. DCA125SSIU4F and Serial No. 7514178, rated at 79 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.0746	gm/bhp-hr
NOx	0.0895	gm/bhp-hr
PM10	0.0149	gm/bhp-hr
PM2.5	0.0148	gm/bhp-hr
SOx	0.0053	gm/bhp-hr
VOC	0.0075	gm/bhp-hr

CONDITIONS:

Fee Schedule: 7 (g)	Rating: 1 device	SIC: 9711	SCC: 20100102	Location/UTM(Km): 505E/3859N
---------------------	------------------	-----------	---------------	---------------------------------

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Commanding Officer, MCLB Barstow, CA
Box 110570 Attn: Air Program Manager
Barstow, CA 92311-5050

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. This certified Tier 4 Final portable compression-ignited internal combustion engine, and any associated air pollution control equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[40 CFR 60.4211(a)]

2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.
[17 CCR 93115.10(d)]

3. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,

b. A cetane index or aromatic content, as follows:

(i) A minimum cetane index of 40; or,

(ii) A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a), 40 CFR 80.510(b), and 40 CFR 60.4207(b)]

Note: Use of CARB certified ULSD fuel satisfies these requirements.

4. This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power has been interrupted. In addition, this engine shall be operated no more than 50 hours per year for testing and maintenance.
[17 CCR 93115.6(a)(3)(A)(1)(c)]

5. The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

a. Date(s) of each use and hours of operation;

b. Reason for use (regular testing & maintenance, NFPA testing & maintenance, emergency, etc.);

c. Monthly and rolling 12 month period operation in terms of fuel consumption (in gallons) and/or total hours (both emergency and non-emergency use, classified as described in b. above);

d. Fuel sulfur concentration as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,

e. Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

6. This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

7. This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(1)(C)]

8. This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.

[District Rule 1302]

9. This engine shall not be used within 500 feet of any K-12 school, residence, hospital, or other sensitive receptor location. Sensitive receptor locations include, but are not limited to, hospitals, schools, and day care centers, and such other locations as the District board or California Air Resources Board may determine.

[District Rule 1320 and H&SC 42301.6]

10. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]