



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

G000566

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: FEBRUARY 2000**

**OWNER OF OPERATOR (Co.#983)**

ExxonMobil Oil Corp/c/o Gilbarco/Veeder-Root  
7300 West Friendly Ave  
Greensboro, NC 27420-2087

**EQUIPMENT LOCATION (Fac.#88)**

ExxonMobil/closed  
Hwys 58 & 395, Kramer Junction  
Boron, CA 93516

**Description:**

GASOLINE DISPENSING FACILITY consisting of:

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	10
89U	10
92U	4

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
P11	AST	G-70-

**CONDITIONS:**

Fee Schedule: 6 (N/A)

Rating: 24 product-nozzles SIC: 5541

SCC: 40600603

Location/UTM(Km):  
451E/3872N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ExxonMobil Oil Corp/c/o Gilbarco/Veeder-Root  
P.O. Box 22087/Attn:CMS Mailstop F-76  
Greensboro, NC 27420-2087

By: **COPY**  
Eldon Heaston  
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on this equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
3. Any modification or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
4. Once in each twelve month period the owner/operator shall conduct and pass a static pressure decay test and verify that the air-to-liquid (A/L) ratio is 1.00 plus/minus 0.10 in accordance with CARB Executive Order G-70-153-AA.
5. These tests shall be conducted in accordance with the District Compliance Test Procedural Manual and the test report received by the District not later than six (6) weeks prior to the expiration date of this permit.