



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

G001130

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 1999

OWNER OF OPERATOR (Co.#132)

Chevron Products Company
6001 Bollinger Canyon Road
San Ramon, CA 94583

EQUIPMENT LOCATION (Fac.#634)

Chevron USA #9-5572
14629 7th Street
Victorville, CA 92392

Description:

GASOLINE DISPENSING FACILITY consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	12
89U	6
92U	6

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-
PII	BAL	G-70-

CONDITIONS:

Fee Schedule: 6 (N/A)

Rating: 24 product-nozzles SIC: 5541

SCC: 99999999

Location/UTM(Km):
472E/3818N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

<p>Chevron Products Company PO Box 6004, Attn: Permit Desk San Ramon, CA 94583</p>

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.

4. The District shall be notified when installation of all piping and control fittings required by aforementioned Rules have been completed. Vapor control piping and fittings shall remain exposed until the District has inspected the installation or given approval to complete backfill.

5. A Gasoline Dispensing Facility Dynamic Back Pressure Test and a Leak Test shall be conducted in accordance with District approval methods on the vapor recovery system.
 - a. These tests shall be performed after dispensing the first 60,000 gallons of gasoline following the modification or the placing of the Phase II vapor recovery system in service. Testing shall, in no case be conducted later than 90 days after placing the Phase II vapor recovery system in service.
 - b. The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.