



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

M003609

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MARCH 2013

OWNER OF OPERATOR (Co.#95)

Barstow Community Hospital
820 East Mountain View Street
Barstow, CA 92311

EQUIPMENT LOCATION (Fac.#186)

Barstow Community Hospital (7th St)
555 S 7th Street
Barstow, CA 92311

Description:

BOILER, STANDBY (NO.2) consisting of: an Orr & Senbower, Inc. boiler, Model No. 3012704, Serial No. 5607094, and rated at 70 hp (2.3 MMBtu/hr).

CONDITIONS:

1. This boiler shall be operated and maintained in strict accord with manufacturer's and/or suppliers recommendations or sound engineering principles.
2. The owner/operator shall use only Commercial Grade Natural Gas to fire this Boiler.
3. This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.
4. The boilers with valid District permits B003610 and M003609 represent two linked boilers, one of which is a standby unit. No more than one of the boilers covered by these permits can be operated simultaneously for any reason.

Fee Schedule: 10 (2c)

Rating: 2300000 Btu

SIC: 8062

SCC: 10300603

Location/UTM(Km):
498E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Barstow Community Hospital
555 S Seventh Street
Barstow, CA 92311

By: **COPY**
Eldon Heaston
Air Pollution Control Officer