



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**RENEWAL**

N001423

Renewal type Permit has no description information.

**EXPIRES LAST DAY OF: JUNE 2026**

## **OWNER OF OPERATOR (Co.#199)**

SBCo Fleet Management Department  
210 N Lena Road  
San Bernardino, CA 92415-0842

## **EQUIPMENT LOCATION (Fac.#853)**

SBCo - Morongo Basin Gov't Center  
6527 White Feather Road  
Joshua Tree, CA 92252

### **Description:**

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

### **FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	20,000	Under Ground
2	Diesel	10,000	Under Ground

### **DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	2
Diesel	2

### **VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	DP	VR-102-B
PII	BAL	G-70-52-AM

Fee Schedule: 5 (b)

Rating: 20000 gallons

SIC: 9199

SCC: 40600603

Location/UTM(Km):  
565E/3778N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fleet Management Department  
210 N Lena Road  
San Bernardino, CA 92415-0842

By: **COPY**  
**Brad Poiriez**  
Executive Director

## CONDITIONS:

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).  
[District Rule 461 - Gasoline Transfer and Dispensing]
  
2. The owner/operator shall maintain a log of all inspections, repairs, maintenance, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.  
[District Rule 461 - Gasoline Transfer and Dispensing]
  
3. Any modifications or changes to the piping or control fittings of the vapor recovery system require prior approval from the District.  
[District Regulation XIII - NSR]
  
4. The gasoline vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by Executive Order (EO) VR-302.  
[CARB Executive Order VR-302]
  
5. Pursuant to the Phase I Executive Order VR-102; the owner or operator shall conduct and pass the following tests no later than 60 days after startup and at least once every year after startup testing; there shall be no more than 12 months between valid Phase I testing dates.
  - a. TP-201.3, Determination of 2 Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities (March 17, 1999)
  - b. TP-201.1B, Static Torque of Rotatable Phase I Adaptors (October 8, 2003), and depending on the system configuration, either TP-201.1C, Leak Rate of Drop Tube/Drain Valve Assembly (October 8, 2003) or TP-201.1D, Leak Rate of Drop Tube Overfill Prevention Devices and Spill Container Drain Valves (October 8, 2003)
  - c. P/V valves in accord with TP-201.1E.
  - d. If a FFS PV-Zero P/V vent valve is used, tests shall be conducted with the valve remaining in its installed position on the vent line(s) in accordance with PV-Zero section of the applicable ARB-Approved Installation, Operation and Maintenance Manual.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Notifications and test results should be sent electronically to [VaporRecoveryTesting@mdaqmd.ca.gov](mailto:VaporRecoveryTesting@mdaqmd.ca.gov)  
[District Rule 461]

6. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.  
[District Regulation XIII]
  
7. EVR 2-Point Phase I Vapor Control Equipment to be maintained in Compliance with Executive Order (EO) VR-102-B.
  
8. Balance Phase II Vapor Control Equipment to be maintained in Compliance with Executive Order G-70-52-AM, dispensers shall be uni-hose type, except that hanging hardware shall be replaced with EVR Phase II Balance Hanging hardware during normal equipment change outs.
  
9. The Owner/Operator has elected to operate without installing EVR Phase II, and therefore must operate with at least 95% ORVR vehicles within the fleet. As such the Owner/Operator must maintain records regarding the fleet vehicles, the ORVR status of each vehicle, method used to determine ORVR status for each vehicle, and the percentage of ORVR vehicles.

This record must be maintained on site for a minimum of two years, and available to District personal upon request.