

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

PERMIT TO OPERATE

N001505

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co.#46)

Victorville, City of 14343 Civic Drive

EQUIPMENT LOCATION (Fac. #70)

Victorville - Fleet Maint Yard 14177 McArt Road Victorville, CA92392

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Victorville, CA92392-2399

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1A	87U	10,000	Under Ground
1B	Diesel	10,000	Under Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	2
Diesel	2

VAPOR CONTROL EQUIPMENT

Туре	Equipment Name	Compliance
PI	OPW	VR-102
PII	HEALY	VR-201-G

Fee Schedule:5 (a) Rating:10000gallons SIC:9199 SCC:40600603 Location/UTM(Km):471E/3822N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Page 1 of 2

Victorville, City of Public Works - Fleet Division

Victorville, CA92392-2399

By: COPY
Brad Poiriez
Air Pollution Control Officer

CONDITIONS:

- 1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).
- [District Rule 461 Gasoline Transfer and Dispensing]
- 2. The owner/operator shall maintain a log of all inspections, repairs, maintenance, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request. [District Rule 461 Gasoline Transfer and Dispensing]
- 3. Any modifications or changes to the piping or control fittings of the vapor recovery system require prior approval from the District. [District Regulation XIII NSR]
- 4.The Enhanced Vapor Recovery (EVR), 2-Point Phase I System shall be tested in accordance with the requirements of Executive Order (EO) VR-102, as stated herein. The owner or operator shall conduct and pass the following tests no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the following test procedures:
- a. TP-201.1B, Static Torque of Rotatable Phase I Adaptors;
- b. Depending on the system configuration, either TP-201.1C, Leak Rate of Drop Tube/Drain Valve Assembly or TP-201.1D, Leak Rate of Drop Tube Overfill Prevention Devices and Spill Container Drain Valve; and,
- c. TP-201.1E, Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

- 5.The Enhanced Vapor Recovery (EVR), Phase II Vapor Recovery System shall be tested in accordance with the requirements of Executive Order (EO) VR-201-G, as stated herein. The owner or operator shall conduct and pass the following testsno later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the following test procedures:
- a. TP-201.3, Determination of 2-Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities (July 26, 2012):
- b. Exhibit 4, Determination of Static Pressure Performance of the Healy Clean Air Seperator;
- c. Exhibit 5, Vapor to Liquid Volume Ratio;
- d. Exhibit 7, Nozzle Bag Test Procedure; and,
- e. Exhibit 8, Required Items in Conducting TP-201.3.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

- 6.The annual throughput of gasoline shall not exceed 600,000 gallons per year. This throughput is established to enable this facility to operate without installing ISD. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required. [District Rule 1320 NSR for Toxic Air Contaminants]
- 7.Enhanced Vapor Recovery (EVR) 2-Point Phase I Vapor Control Equipment must be maintained in compliance with Executive Order (EO) VR-102.
- 8.Assist EVR Phase II without ISD Equipment must be maintained in compliance with Executive Order (EO) VR-201-G.
- 9.In accordance with the EVR implementation time line, and based on this facility's throughput limit, In-Station-Diagnostics (ISD) is not required. If the owner/operator wishes to increase throughput allowance, ISD must be installed in accordance with the EVR timeline. Prior to installing this system, a District approved Authority to Construct permit must be obtained.

Page 2 of 2 Permit: N001505 Issue Date: 07/16/2025