



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

## AUTHORITY TO CONSTRUCT

N001530

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

**EXPIRES LAST DAY OF: DECEMBER 2026**

### OWNER OF OPERATOR ( Co. #1163 )

CaSta Highway Patrol  
PO Box 942898  
Sacramento, CA 94298

### EQUIPMENT LOCATION ( Fac. #891 )

CHP - Barstow  
300 E Mountain View  
Barstow, CA 92311

#### Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of: A 10,000 gallon Modern Model SuperVault MH Double-wall Tank (AST) Serial No: 106072, equipped with Morrison Brothers Phase I EVR. Facility elevation is 2314 feet above MSL.

#### FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	10,000	Above Ground

#### DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	2

#### VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	MB	VR-402
SL	SL	VR-301

Fee Schedule: 5 (b)

Rating: 10000 gallons

SIC: 9221

SCC: 40600131

Location/UTM(Km):  
497E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CaSta Highway Patrol  
PO Box 942898  
  
Sacramento, CA 94298

By: **COPY**  
**Brad Poiriez**  
Executive Director

## **CONDITIONS:**

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).  
[District Rule 461 - Gasoline Transfer and Dispensing]

2. The owner/operator shall maintain a log of all inspections, maintenance and repairs, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.  
[District Rule 461 - Gasoline Transfer and Dispensing; Executive Order VR-402]

3. The owner/operator has elected to maintain this equipment as exempt from Phase II Enhanced Vapor Recovery requirements by refueling a fleet with at least 95%+ onboard refueling vapor recovery system (ORVR) vehicles. To ensure compliance the owner/operator shall keep records of the make, model, model year, and Vehicle Identification number of all vehicles refueled at the facility. These records shall be maintained on the premises for at least two (2) calendar years.  
[District Rule 461(D)(3) and (E)(6) - Gasoline Transfer and Dispensing]

4. Any modifications or changes to the piping, control fittings, or configurations of the vapor recovery system require prior approval from the District.  
[District Regulation XIII - NSR]

5. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-402 for EVR Phase I and VR-301 (Standing Loss Control). Vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by the Executive Order.  
[Executive Orders VR-402 and VR-301]

6. The Enhanced Vapor Recovery (EVR), Phase I Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Orders VR-301 and VR-402, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Orders VR-301 and VR-402]]

7. Pursuant to Executive Order VR-402, Exhibit 2, Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by technicians certified on Morris Brothers equipment.  
[Executive Order VR-402]

8. The annual throughput of gasoline shall not exceed 100,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.  
[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

9. Facility shall maintain a record of what coating system that is certified by CARB they elected to use in order to comply with the standing loss requirements. please refer to Exhibit 1 of VR-301 and/or the link for the list of coating manufacturer and products certified by CARB <https://ww2.arb.ca.gov/resources/documents/frequently-asked-questions-vapor-recovery-requirements-gasoline-dispensing>.  
[Executive Order VR-301]

10. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.  
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]