MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N001537

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2009

OWNER OF OPERATOR (Co.#90)

Omya (California) Inc
7299 Crystal Creek Road
Lucerne Valley, CA 92356

EQUIPMENT LOCATION (Fac.#461)

Omya - Main Plant
7299 Crystal Creek Road
Lucerne Valley, CA 92356

Description:
GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	10,000	Under Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	VR-102-C
PII	BAL	G-70-17-AD

CONDITIONS:

Fee Schedule: 5 (a) Rating: 10000 gallons SIC: 1422 SCC: 40600603 Location/UTM(Km): 505E/3805N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Omya (California) Inc
7225 Crystal Creek Rd
Lucerne Valley, CA 92356

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

1. This gasoline dispensing facility is in the process of being decommissioned, and as such, shall NOT receive any additional fuel deliveries.

2. Fuel may be dispensed out of this GDF until depleted, but shall not operate past June 30, 2009.

3. The owner/operator shall submit a request to Cancel Permit, to the District, no later than June 30, 2009.

4. The owner/operator shall maintain this equipment in accordance with Executive Order G-70-17-AD, until the time that this equipment is no longer in service.

5. Once fuel has been removed from tank, the tank shall be capped, and sealed so as to minimize fugitive emissions until the tank is physically removed from site.

6. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and available to the District upon request.