



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

N001550

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: APRIL 2026**

**OWNER OF OPERATOR (Co.#69)**

Southern California Edison  
P.O. Box 5085  
Rosemead, CA 91770

**EQUIPMENT LOCATION (Fac.#902)**

SCE - Barstow Service Center  
1820 Rimrock Road  
Barstow, CA 92311

**Description:**

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of: Bulk loading system includes: two position tank truck loading system consisting of: A. One (1) 2" dia. X 8' L. Gasoline hose with an OPW dry break coupler for bottom loading. B. One (1) 3" d1a. X 8' L. Gasoline vapor recovery hose with an OPW camlock quick connect 4x3 coupler. C. One (1) 2" dia. X 8' L. Diesel hose with an OPW dry break coupler for bottom loading (exempt).

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1A	87U	6,000	Above Ground
1B	Diesel	6,000	Above Ground

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	1
Diesel	1

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	OPW	VR-401

Fee Schedule: 5 (b)

Rating: 12000 gallons

SIC: 4911

SCC: 40600603

Location/UTM(Km):  
501E/3859N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison  
P.O. Box 5085  
  
Rosemead, CA 91770

By: **COPY**  
**Brad Poiriez**  
Executive Director

Type	Equipment Name	Compliance
PII	BAL	G-70-162-A

**CONDITIONS:**

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).  
 [District Rule 461 - Gasoline Transfer and Dispensing]

2. The owner/operator shall maintain a log of all inspections, repairs, maintenance, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.  
 [District Rule 461 - Gasoline Transfer and Dispensing]

3. Any modifications or changes to the piping or control fittings of the vapor recovery system require prior approval from the District.  
 [District Regulation XIII - NSR]

4. The Phase I EVR Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Order VR-401 and Phase II pre-EVR tested in accordance with Executive Order G-70-162, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov  
 [District Rule 461 - Gasoline Transfer and Dispensing, Executive Orders G-70-162 and VR-401]

5. Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by OPW Certified Technicians.  
 [Executive Order VR-401]

6. Maintenance Intervals for OPW Tank Gauge Components, Dust Caps, Emergency Vents, Phase I Product and Vapor Adapters, and Spill Container Drain Valve, shall be conducted by an OPW trained technician on an annual basis.  
 [Executive Order VR-401]

7. The annual throughput of gasoline shall not exceed 600,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required.  
 [District Rule 1320 - NSR for Toxic Air Contaminants]

8. The owner/operator must install, maintain, and operate EVR Phase I equipment in compliance with CARB Executive Order VR-401, and Phase II equipment in accordance with G-70-162-A with the exception that hanging hardware shall be EVR Balance Phase II-type (VST or other CARB Approved EVR Phase II Hardware).