



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N002417

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 1998

OWNER OF OPERATOR (Co.#391)

Arizona Pipeline Co
PO Box 401865
Hesperia, CA 92340-1865

EQUIPMENT LOCATION (Fac.#1058)

Arizona Pipeline Co
17372 Lilac
Hesperia, CA 92345

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-
PII	BAL	G-70-

CONDITIONS:

Fee Schedule: 5 (a)

Rating: 8000 gallons

SIC: 1623

SCC: 99999999

Location/UTM(Km):
473E/3808N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Arizona Pipeline Co
PO Box 401865
Hesperia, CA 92340-1865

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.