



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N002645

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2001

OWNER OF OPERATOR (Co.#457)

Victor Valley Community College District
18422 Bear Valley Road
Victorville, CA 92392

EQUIPMENT LOCATION (Fac.#1127)

Victor Valley Community College District
18422 Bear Valley Road
Victorville, CA 92392

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-
PII	BAL	G-70-

CONDITIONS:

1. The toll-free telephone number that must be posted is 1-800-635-4617.

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such

Fee Schedule: 5 (a) Rating: 6000 gallons SIC: 8221 SCC: 99999999 Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Community College District
18422 Bear Valley Road

Victorville, CA 92392

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

3.Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.