

## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

# **INACTIVE**

N004104

Inactive type Permit has no description information.

# **EXPIRES LAST DAY OF: FEBRUARY 2005**

# OWNER OF OPERATOR (Co.#3064)

EQUIPMENT LOCATION (Fac.#1422)

ASB - El Centro 19005 Wiley's Well Road Blythe,CA92225 Ironwood State Prison - Site 2 19025 Wileys Well Road Blythe,CA92226

# **Description:**

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

#### **FUEL TANKS**

Tank No. Material Stored	ed Volume (US Gallons)	Above/Underground
--------------------------	------------------------	-------------------

### **DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	2
Diesel	2

# **VAPOR CONTROL EQUIPMENT**

Туре	Equipment Name	Compliance
PI	DP	G-70-
PII	BAL	G-70-

#### **CONDITIONS:**

1. The toll-free telephone number that must be posted is 1-800-635-4617.

Fee Schedule:5 (b) Rating:16000gallons SIC:9223 SCC:99999999 Location/UTM(Km):725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ASB - El Centro 19005 Wiley's Well Road Blythe,CA92225

By: COPY
Brad Poiriez
Air Pollution Control Officer

3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.	2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.					
	3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.					

Page 2 of 2 Permit: N004104 Issue Date: 03/01/2004