

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

N005073

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JANUARY 2025

OWNER OF OPERATOR (Co.#2733)

NextEra Energy Capital Holdings, Inc. 700 Universe Blvd.
Juno Beach,FL33408

EQUIPMENT LOCATION (Fac. #941)

Resurgence Solar & BESS 41100 Highway 395 Boron,CA93516

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:SEGS VI

FUEL TANKS

Tank No. Material Stored	Volume (US Gallons)	Above/Underground
--------------------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Туре	Equipment Name	Compliance
PII	BAL	G-70-167
PI	СО	G-70-167

CONDITIONS:

Fee Schedule:5 (a) Rating:5000gallons SIC:4911 SCC:40600603 Location/UTM(Km):450E/3874N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NextEra Energy Capital Holdings, Inc. 700 Universe Blvd.
Juno Beach,FL33408

By: COPY
Brad Poiriez
Air Pollution Control Officer

1.The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461 - Gasoline Transfer and Dispensing]

- 2.The owner/operator shall maintain a log of all inspections, maintenance and repairs, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request. [District Rule 461 Gasoline Transfer and Dispensing]
- 3.Any modifications or changes to the piping, control fittings, or configurations of the vapor recovery system require prior approval from the District.

[District Regulation XIII - NSR]

- 4. The vapor vent pipes are to be equipped with pressure relief valves.
- 5.The Phase I and II Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Order G-70-167, at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdagmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order G-70-167]

6. The annual throughput of gasoline shall not exceed 60,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility is required to submit to the District an application to modify the permit which may require a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required.

[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

7.All Vapor Control Equipment must be installed and maintained in compliance with CARB Executive Order G-70-167. The owner or operator shall perform the required maintenance as specified in ARB-Approved Installation and Maintenance Manual, including PV maintenance, as applicable.

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order G-70-167, 40 CFR 63, Subpart CCCCCC]

- 8. Facility-wide emissions must be less than:
- a) 20 tons per year of NOx,
- b) 20 tons per year of VOC,
- c) 15 tons per year of PM10 (basis: offsets),
- d) 10 tons per of any single Hazardous Air Pollutant, and
- e) 25 tons per year of any combination of any Hazardous Air Pollutant.

Facility-wide emissions shall be calculated and recorded, in tons, on a calendar month basis and totaled for each consecutive twelvemonth basis. For emergency engines, only emissions generated during testing and maintenance shall apply toward the facility-wide emission limits. These records shall be maintained as current for a minimum of five (5) years, and made available upon District, State and/or Federal request.

[District Rule 221(B) and (C) - Basis: Voluntary Emission Limitations - below Title V]

Page 2 of 2 Permit: N005073 Issue Date: 01/23/2024