



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

N005100

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co.#199)

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

EQUIPMENT LOCATION (Fac.#1117)

SBCo - Apple Valley Maintenance Yard
11923 Joshua Road
Apple Valley, CA 92307

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of: The AST meets one of the Phase I EVR exemptions, as it does not receive gasoline through top fill, as listed in the MDAQMD advisory dated 04/14/2014. Facility elevation is 3016 feet above MSL.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	6,000	Above Ground
2	Diesel	6,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-132-B
PII	BAL	G-70-132-B

Fee Schedule: 5 (a)

Rating: 6000 gallons

SIC: 9199

SCC: 40600603

Location/UTM(Km):
482E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

Type	Equipment Name	Compliance
SL	SL	VR-301

CONDITIONS:

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).
[District Rule 461 - Gasoline Transfer and Dispensing]

2. The owner/operator shall maintain a log of all inspections, maintenance and repairs, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
[District Rule 461 - Gasoline Transfer and Dispensing]

3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
[District Regulation XIII - NSR]

4. The gasoline vapor vent lines must be equipped with a Husky 5885 pressure/vacuum vent valve; or, as otherwise allowed by Executive Order VR-301.
[District Rule 204; Executive Order VR-301]

5. The Pre-Enhanced Vapor Recovery (Pre-EVR), Phase I and II Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Orders VR-301 and G-70-132-B, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov
[District Rule 461 - Gasoline Transfer and Dispensing, Executive Orders VR-301, Table 3-1, G-70-132-B]

6. The annual throughput of gasoline shall not exceed 450,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.
[District Rule 461(E)(3) and District Rule 1320 - NSR for Toxic Air Contaminants, CARB CP-206, Section 2.4.6, CARB CP-206, Table 2-2]

7. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Pre-EVR Executive Order G-70-132-B for Phase I and VR-301 (Standing Loss Control). Additionally, Phase II Vapor Recovery System shall be installed and maintained per G-70-132-B with the exception that hanging hardware shall be EVR Balance Phase II type hanging hardware.
[Executive Orders G-70-132-B, and VR-301; CARB CP-206, Table 2-2]

8. The owner/operator must ensure the exterior tank coating and pressure/vacuum vent valve retrofits occur no later than April 1, 2013. The owner/operator must retain records of the retrofits on site and make available to State and District personnel upon request.
[District Rule 204, Executive Order VR-301]

9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]