



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N008009

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2019

OWNER OF OPERATOR (Co. #681)

General Atomics - LSNC
3550 General Atomics Court
San Diego, CA 92121-1194

EQUIPMENT LOCATION (Fac. #1648)

G A Aeronautical Sys - El Mirage Rd
73 El Mirage Airport Road
Adelanto, CA 92301

Description:

AVIATION STORAGE AND DISPENSING (AVGAS TRUCK) consisting of: International 1982 1700 Tank Truck with a 45 gallon per minute Gorman/Rupp pump.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	AvG	1,200	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
AvG	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted in these conditions.

Fee Schedule: 5 (a)

Rating: 1200 gallons

SIC: 3721

SCC: 40600138

Location/UTM(Km): 459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

General Atomics - LSNC
ATTN: LSNC

San Diego, CA 92186-5608

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

2.The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461 - Gasoline Transfer and Dispensing]

3.The owner/operator shall maintain a log of all inspections, maintenance and repairs, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461 - Gasoline Transfer and Dispensing]

4.Any modifications or changes to the piping, control fittings, or configurations of the vapor recovery system require prior approval from the District.

ATC Only: The District must be notified when installation of all piping and control fittings is completed. Vapor control piping and fittings must remain exposed until the District has inspected the installation or given approval to complete backfill. Notification may be made via phone, or via email request to reporting@mdaqmd.ca.gov

[District Regulation XIII - NSR]

5.The vapor vent pipes are to be equipped with pressure relief valves.

6.The owner/operator shall conduct EPA Method 27 - Determination of Vapor Tightness of Gasoline Delivery Tank Using Pressure Vacuum Test within 60 days of construction completion and every thirty six months thereafter. The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing]

7.5. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility is required to submit to the District an application to modify the permit which may require a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required.

[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

8.This equipment shall only be used to fuel or defuel aircraft,or tanks which are solely used for the fueling of aircraft, within the El Mirage Airport Facility. Other fueling or defueling activities shall only be performed with the express written consent of the District.

9.This equipment shall only store and dispense aviation gasoline fuel.