



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N010308

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2020

OWNER OF OPERATOR (Co.#69)

Southern California Edison
P.O. Box 5085
Rosemead, CA 91770

EQUIPMENT LOCATION (Fac.#1436)

SCE - Blythe
505 14th Avenue
Blythe, CA 92225

Description:

MOBILE FUEL DISPENSING EQUIPMENT consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1A	Diesel	750	Above Ground
1B	87U	750	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-193
PII	AST	G-70-193

Fee Schedule: 5 (a)

Rating: 800 gallons

SIC: 5541

SCC: 40600131

Location/UTM(Km):
725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison
P.O. Box 5085

Rosemead, CA 91770

By: **COPY**
Brad Poiriez
Executive Director

CONDITIONS:

1. The toll-free telephone number that must be posted is 1-800-635-4617.

[District Rule 461]

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to District personnel upon request.

[District Rule 461]

3. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District.

[District Rule 461]

4. The vapor vent pipe shall be equipped with a pressure relief valve.

[District Rule 461]

5. This tanker truck shall be equipped and operated in compliance with the National Air Toxic Standards for Gasoline Dispensing Facilities (GDF) (40 CFR 63, Subpart CCCCCC). In the event of conflict with these permit conditions and the NESHAP, the more stringent requirements shall govern.

[40 CFR 63, Subpart CCCCCC]

6. Pursuant to District Rule 461, prior to dispensing any fuel, this tanker truck shall have a valid certification of vapor integrity as defined by the applicable Air Resources Board Certification and Test Procedures, pursuant to Health and Safety Code Section 41962(9) and the California Administrative Code Title 17, Section 94004. A copy of the current testing certificate must be maintained in the vehicle at all times and available to District personnel upon request.

[District Rule 461, District Rule 1303]

7. The annual throughput of Aviation Gasoline shall not exceed 500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition, a public notice and/or comment period may be required.

[District Rule 1303]

8. Pursuant to Executive Order G-70-193 and Title 17 of the California Code of Regulations Section 94014: "Certification of Vapor Recovery Systems for Cargo Tanks," the owner or operator shall conduct and pass the following tests every twelve (12) months, using the latest adopted version of the following test procedures:

CP-204: Certification Procedure for Vapor Recovery Systems of Cargo Tanks:

a. TP-204.1, Determination Of Five Minute Static Pressure Performance Of Vapor Recovery Systems Of Cargo Tanks.

G-70-193: Certification of the Hill-Vac Vapor Recovery System for Cargo Tank Motor Vehicle Fueling Systems:

a. Exhibit 3, Vapor Return Line Integrity Test;

b. Exhibit 4, Fill Pipe Pressure Regulation Requirements; and,

c. Exhibit 5, Ten-Gallon Per Minute Maximum Fueling Rate Compliance Verification Procedure.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

[Title 17 CCR 94014]

9. The o/o shall install, maintain, and operate this equipment in compliance with CARB Executive Order G-70-10-A.