



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

N010831

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: JANUARY 2027**

**OWNER OF OPERATOR (Co.#1786)**

Victor Valley Transit Authority  
17150 Smoketree Street  
Hesperia, CA 92345

**EQUIPMENT LOCATION (Fac.#3181)**

Victor Valley Transit Authority - Smoke Tree  
17150 Smoke Tree  
Hesperia, CA 92345

**Description:**

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	12,000	Under Ground

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	3

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	OPW	VR-102
PII	BAL	VR-203

**CONDITIONS:**

Fee Schedule: 5 (a)

Rating: 10000 gallons

SIC: 9621

SCC: 40600603

Location/UTM(Km):  
473E/3808N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Transit Authority  
Attn: Angelina Calderone  
  
Hesperia, CA 92345

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461 - Gasoline Transfer and Dispensing]

2. The owner/operator shall maintain a log of all inspections, repairs, maintenance, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461 - Gasoline Transfer and Dispensing]

3. Any modifications or changes to the piping or control fittings of the vapor recovery system require prior approval from the District.

[District Regulation XIII - NSR]

4. The Enhanced Vapor Recovery (EVR), Phase I and II Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Orders, VR-102 and Order VR-203, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to [vaportest@avaqmd.ca.gov](mailto:vaportest@avaqmd.ca.gov).

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Orders VR-102 and VR-203]

5. The owner/operator shall perform annual maintenance on their PV valve(s) pursuant to the instructions in the IOM, followed by testing per the above condition. Records shall be kept of the required maintenance and subsequent test and results.

[Executive Order VR-102]

6. The annual throughput of gasoline shall not exceed 600,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility is required to submit to the District an application to modify the permit which may require a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required.

[District Rule 1401 - NSR for Toxic Air Contaminants; District Rule 212(C)(3); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

7. Enhanced Vapor Recovery (EVR), 2-Point Phase I Vapor Control Equipment must be installed and maintained in compliance with CARB Executive Order VR-102. The owner or operator shall perform the required maintenance as specified in ARB-Approved Installation and Maintenance Manual for the Phase I Vapor Recovery System, including PV maintenance, as applicable.

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order VR-102, 40 CFR 63, Subpart CCCCCC]

8. Enhanced Vapor Recovery (EVR), Phase II Vapor Control Equipment must be installed and maintained in compliance with CARB Executive Order VR-203.

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order VR-203, 40 CFR 63, Subpart CCCCCC]