



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N011014

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2016

OWNER OF OPERATOR (Co.#866)

Southern California Logistics Airport
18374 Phantom
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#3149)

Victorville - SCLA Fuel Farm #2
18373 Gateway
Victorville, CA 92394

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
101	AvG	10,000	Under Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
AvG	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	VR-401-B

CONDITIONS:

Fee Schedule: 5 (a)

Rating: 10000 gallons

SIC: 4581

SCC: 40600603

Location/UTM(Km):
464E/3827N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Logistics Airport
18374 Phantom
Victorville, CA 92394

By: **COPY**
Brad Poiriez
Executive Director

1. The toll-free telephone number that must be posted is 1-800-635-4617.

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and available to the District upon request. Records of Maintenance, Tests, Inspections, and Test Failures shall be maintained and available to District personnel upon request; record form shall be similar to the Maintenance Record form indicated in EO VR-401-B, Figure 2N

[EO VR-401; Rule 461]

3. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District.

4. Pursuant to EO VR-401-B, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by EO.

5. The o/o shall perform the following tests within 60 days of construction completion and annually thereafter in accord with the following test procedures:

- a. Determination of Static Pressure Performance of Vapor Recovery Systems at Gasoline Dispensing Facilities with Aboveground Storage Tanks shall be conducted per EO VR-401-B Exhibit 4. Exhibit 4,
- b. Phase I Adapters, Emergency Vents, Spill Container Drain Valve, Dedicated gauging port with drop tube and tank components, all connections, and fittings shall NOT have any detectable leaks; test methods shall be per EO VR-401-B Table 2-1, and
- c. Liquid Removal Test (if applicable) per TP-201.6, and

Summary of Test Data shall be documented on a Form similar to EO VR-401-B Form 1

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

The District shall receive passing test reports no later than six (6) weeks prior to the expiration date of this permit.

6. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-401-B for EVR Phase I, and Standing Loss requirements:
<http://www.arb.ca.gov/vapor/eos/eo-vr401/eo-401.htm>.

7. Pursuant to EO VR-401-B: Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by OPW Certified Technicians.

8. Pursuant to EO VR-401-B, Maintenance Intervals for OPW; Tank Gauge Components; Dust Caps Emergency Vents; Phase I Product and Vapor Adapters, and Spill Container Drain Valve, shall be conducted by an OPW trained technician annually.

9. The annual throughput of aviation gasoline shall not exceed 500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required.

10. The o/o shall; install, maintain, and operate EVR Phase I in compliance with CARB Executive Order VR-401-B; Phase II vapor is not required; see condition 11.

11. This equipment is exempt from Phase II vapor recovery, and as such is prohibited from dispensing fuel to motor vehicle registered vehicles such as automobiles, and trucks.

12. This Phase I equipment has not been certified with use with aviation gasoline. It is the owner/operators responsibility to ensure fuel-equipment compatibility; the MDAQMD assumes no responsibility for any fuel-equipment incompatibilities.

13. The owner/operator (o/o) shall completely offset the maximum annual potential-to-emit for permitted and unpermitted equipment used in the support/operations of aircraft and/or an airfield, including aerospace ground equipment, added after April 1, 1999 at this facility that replace or perform essentially the same function as retired equipment associated with the shutdown of George Air Force Base for which emission reduction credits were issued.

The o/o shall maintain a copy of the ERC contract between the Southern California International Airport Authority and the MDAQMD plus a current, on-site list of replacement equipment cross referenced to the ERC contract; said list shall include equipment description, serial or identifying number, date equipment was offset, and maximum annual potential-to-emit.

14. The emissions from this facility shall be less than the following limits:

- a. 8 tons per year of any single HAP or 20 tons per year of any combination of HAPs on a 12 month calendar year basis
- b. 15 tons of PM10 per year on a 12 month calendar year basis
- c. 20 tons of NOx per year on a 12 month calendar year basis
- d. 20 tons of VOC per year on a 12 month calendar year basis
- e. 20 tons of CO per year on a 12 month calendar year basis
- f. 20 tons of SOx per year on a 12 month calendar year basis
- g. 8 ton/year of any HAP and 20 ton/year of any combination of HAP

Compliance with this limit shall be verified with monthly facility emission summaries and an annual emissions inventory. Monthly emissions summaries shall be calculated using a District-approved method, with at least the last two years of monthly emissions summaries maintained and available to be provided to District, State or Federal personnel upon request. The facility must also submit an accurate criteria pollutant emissions inventory to the District, in a format approved by the District, upon request. A comprehensive emission inventory including both criteria pollutants and HAP/TAC shall be submitted every third submission.