



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

N013080

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JULY 2018**

**OWNER OF OPERATOR (Co.#2417)**

The SOCO Group, Inc  
5962 Priestly Drive  
Carlsbad, CA 92008

**EQUIPMENT LOCATION (Fac.#3846)**

Barnard Pipeline - Newberry Springs  
31411 Newberry Springs  
Newberry Springs, CA 92365

**Description:**

GASOLINE DISPENSING FACILITY, NON-RETAIL consisting of: a Hoover Containment/Lube Cube, Model 147000, Serial No. LDP-7074, painted with certified paint, equipped with a Morrison Brothers Phase I EVR system.

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	1,000	Above Ground

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	1

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	MB	VR-402
PII	AST	G-70-52-AM

**CONDITIONS:**

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 5172

SCC: 40600306

Location/UTM(Km):  
530E/3853N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

The SOCO Group, Inc  
5962 Priestly Drive  
Carlsbad, CA 92008

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461]

2. The owner/operator shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and available to the District upon request. Records of maintenance, tests, inspections, and test failures must be maintained and available to District personal upon request. The record form must be similar to the Maintenance Record form indicated in Executive Order VR-402.

[District Rule 461; Executive Order VR-402]

3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.

[District Regulation XIII]

4. Pursuant to Executive Order's VR-402 (PI EVR) and VR-302 (Standing Loss Control), vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by the Executive Order.

5. The owner/operator shall perform the following tests within 60 days of construction completion, and at least once in every twelve month period in accordance with the following test procedures:

- a. Determination of Static Pressure Performance Test per EO VR-402, Exhibit 6 (2-inch test);
- b. Liquid Removal Test per TP-201.6, TP-201.6C or Exhibit 5 (as applicable);
- c. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E; and,
- d. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations; per CARB Method 21.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to

VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461; Executive Orders VR-402 and G-70-52-AM]

6. Pursuant to Executive Order VR-402, Exhibit 2, Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by Morrison Brothers Certified Technicians.

7. The annual throughput of gasoline shall not exceed 60,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.

[District Regulation XIII; Health & Safety Code 44341 - 44342]

8. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-402 for EVR Phase I and VR-302 (Standing Loss Control). Additionally, Phase II Vapor Recovery System shall be installed and maintained per G-70-52-AM with the exception that hanging hardware shall be EVR Balance Phase II type hanging hardware (VST or other CARB Approved EVR Phase II Hardware).

[Executive Orders G-70-116-F, VR-402 and VR-302]

9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]