



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N014030

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2025

OWNER OF OPERATOR (Co.#2610)

Vantex Service Corporation
P.O. Box 220
Manchaca, TX 78652

EQUIPMENT LOCATION (Fac.#4033)

Vantex Service Corporation
Camp Wilson
Twentynine Palms, CA 92277

Description:

GASOLINE DISPENSING FACILITY, NON-RETAIL consisting of: an existing aboveground storage tank manufactured by Safe-T-Tank, Model LS-1000-SPB-4D12. Exterior coating updated to P.P.C. White Gloss CARB Approved Urethane.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	1,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	MB	VR-402

CONDITIONS:

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 7359

SCC: 40300603

Location/UTM(Km):
577E/3796N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Vantex Service Corporation
P.O. Box 220
Manchaca, TX 78652

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.

[District Rule 461 - Gasoline Transfer and Dispensing]

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and available to the District upon request. Records of Maintenance, Tests, Inspections, and Test Failures shall be maintained and available to District personal upon request; record form shall be similar to the Maintenance Record form indicated in EO VR-402. Inspections may be conducted on a monthly basis.

[District Rule 461 - Gasoline Transfer and Dispensing]

3. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District.

[District Regulation XIII - NSR]

4. Pursuant to EO VR-402, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by the executive order.

[District Rule 461 and Executive Order VR-402]

5. The o/o shall perform the following tests annually in accord with the following test procedures:

a. Determination of Static Pressure Performance of Vapor Recovery Systems at Gasoline Dispensing Facilities with Aboveground Storage Tanks shall be conducted per EO VR-402;

b. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E;

c. Phase I Adapters, Emergency Vents, Spill Container Drain Valve, Dedicated gauging port with drop tube and tank components, all connections, and fittings shall NOT have any detectable leaks; test methods shall be per EO VR-402-D Table 2-1.

Summary of Test Data shall be documented on a Form similar to EO VR-402 Form 1.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to

VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Orders VR-402 and 404]

6. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-402 for EVR Phase I, and EO VR-302, Standing Loss requirements.

[District Rule 461 and Executive Order VR-402]

7. Pursuant to EO VR-402, Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by Morrison Bros. Certified Technicians or as allowed by Executive Officer.

[District Rule 461 and Executive Order VR-402]

8. Pursuant to EO VR-402, Maintenance Intervals for Morrison Bros. Tank Gauge Components, Dust Caps Emergency Vents, Phase I Product and Vapor Adapters, and Spill Container Drain Valve, shall be conducted by an Morrison Bros. trained technician on an annual basis.

[District Rule 461 and Executive Order VR-402]

9. The annual throughput of gasoline shall not exceed 60,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year.

[District Rule 204; H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

10. The owner/operator shall only fuel motor vehicles where 95 percent of the fleet vehicles are equipped with onboard refueling vapor recovery (ORVR) systems. The o/o shall keep a record of the make, model, model year, and vehicle identification number of all vehicles refueled by this equipment. These records shall be maintained on the premises for at least two (2) calendar years.

[District Rule 461]