



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T001076

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2001

OWNER OF OPERATOR (Co.#69)

Southern California Edison
P.O. Box 5085
Rosemead, CA 91770

EQUIPMENT LOCATION (Fac.#4)

SCE - EPTC / Coolwater Tanks
37310 Santa Fe Street
Daggett, CA 92327

Description:

TANK NO. 2 - STORAGE consisting of: Flooring Roof, Pontoon type, 222' diameter x 48'H with resilient Toroid-type primary seal enveloped in polyurethane sheet and HMT welded tank, secondary seal. This tank has a total capacity of 13.8 million gallons of Distillate oil fuel.

CONDITIONS:

1. There shall be no holes, tears or openings in either the primary or secondary seals which allow the uncontrolled emission of VOC.
2. Gaps between the tank shell and the primary seal shall not exceed 1/8" for an accumulative length of 95% of the seal circumference and shall not exceed 1/2" for the remaining 5% of accumulative length.
3. Gaps between the tank shell and the secondary seal shall not exceed 1/8" for an accumulative length of 95% of the seal circumference and shall not exceed 1/2" for the remaining 5% of accumulative length.
4. Secondary seal shall extend from the roof of the tank shell and shall not be attached to the primary seal.
5. Secondary seal shall allow easy insertion of a 1/2" wide probe to facilitate primary seal gap measurement.
6. All gauge hatches, roof supports, manholes, automatic bleeder vents, rim vents, gauge wells, etc., shall be equipped with vapor-tight seals or breather vents set at no less than 10% of the maximum allowable working pressure of the roof.

Fee Schedule: 5 (d) Rating: 13800000 gallons SIC: 4941 SCC: 99999999 Location/UTM(Km): 513E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison
P.O. Box 5085

Rosemead, CA 91770

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

7.All openings in the tank roof shall be equipped with a projection which extends below the liquid surface.

8.Emergency roof drain shall be equipped with slotted membrane fabric cover, or equivalent, which covers at least 90% of the drain area.

9.The permittee shall maintain an accurate record of the Reid Vapor Pressure and storage temperature of liquid stored in this tank; this record shall be maintained for a minimum of two years and shall be made available to District personnel upon request. True vapor pressure of liquid stored shall not exceed 11.0 psia.