



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T002623

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2004

OWNER OF OPERATOR (Co.#22)

BNSF Railway Company
740 East Carnegie Drive
San Bernardino, CA 92408

EQUIPMENT LOCATION (Fac.#236)

BNSF Railway Co - Barstow
200 North Avenue H
Barstow, CA 92311

Description:

TANK, WASTE OIL STORAGE consisting of: Waste Oil Storage Tank, 17,233 gal.

EQUIPMENT

Capacity	Equipment Description
17233	Waste Oil Storage Tank

CONDITIONS:

1. Only waste oil generated by the Burlington Northern and Santa Fe Railroad Company at the Barstow Rail Yard shall be stored in this waste oil tank. Other hazardous or toxic material shall not be stored in this tank.
2. All flanges, seals, pumps and other appurtenant equipment shall be maintained to prevent loss of volatile fractions.
3. All waste oil stored in this tank shall have a Reid Vapor Pressure less than 1.55 pounds per square inch (80 mm Hg).

Fee Schedule: 5 (b)

Rating: 20000 gallons

SIC: 4013

SCC: 99999999

Location/UTM(Km):
493E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

BNSF Railway Company
740 East Carnegie Dr

San Bernardino, CA 92408-3571

By: **COPY**
Brad Poiriez
Executive Director

4. The owner/operator (o/o) shall maintain an operator's log for this tank which, as a minimum, contains: source of waste oil, date and volume (or weight) of waste oil sent to outside refiners, the hauler, and results of the Reid Vapor Pressure Test, if performed. The log shall be maintained current, on-site for a minimum of 2 years and presented to District personnel on request.

5. The o/o shall comply with all applicable Rules and Regulations of the District. Applicable rules include but are not limited to Regulation IV.

6. This equipment shall only be operated/maintained in strict accord with the manufacturer's/supplier's recommendations and/or sound engineering principles.