



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T002624

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: SEPTEMBER 2026

OWNER OF OPERATOR (Co. #22)

BNSF Railway Company
740 East Carnegie Drive
San Bernardino, CA 92408

EQUIPMENT LOCATION (Fac. #236)

BNSF Railway Co - Barstow
200 North Avenue H
Barstow, CA 92311

Description:

FUEL DISPENSING FACILITY, DIESEL LOCOMOTIVES consisting of: East Main Line fuel station (tank 0033) with 8 diesel fueling nozzles and West Main Line (tank 1607) with 8 diesel fueling nozzles. Equipment elevation is 2147 feet above sea level.

EQUIPMENT

Capacity	Equipment Description
30000	Tank 0033; 11 ft. diameter, 42 ft. long
34000	Tank 1607; 9.58 ft. diameter, 67.33 ft. long
0	Diesel service station with 39 diesel fueling nozzles serviced from two tanks (T001118 and T005103). These tanks are manifolded.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 1302]

Fee Schedule: 5 (b)

Rating: 64000 gallons

SIC: 4013

SCC: 40600651

Location/UTM(Km):
493E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

BNSF Railway Company
740 East Carnegie Dr

San Bernardino, CA 92408-3571

By: **COPY**
Brad Poiriez
Executive Director

2. The owner/operator shall log the date and volume of diesel fuel dispensed. This log shall be maintained onsite for a minimum of three (3) years and shall be made available to District, State or Federal personnel upon request.

[District Rule 204]

3. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]