



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T002741

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2002

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA 923105085

Description:

TANK #9 (BLDG 630) consisting of: Three storage tanks @ 5,000 gallon each, for used oil or contaminated fuel above the secondary containment 57,000 gallon, lined concrete, underground tank.

CONDITIONS:

1. Hazardous or toxic material shall not be stored in this tank. Only internal combustion engine crankcase drainage oil or contaminated fuel may be stored in these tanks.
2. The owner/operator (o/o) shall notify the District, in writing, thirty days prior to making any change in the type petroleum product stored in this tank. Compliance with District Rules shall be assured by obtaining a modified permit for the proposed petroleum product prior to change of product to be stored in this tank.
3. Used crankcase oil and contaminated fuel shall not be stored in the same tank at the same time.
4. The o/o shall maintain an operators log for this tank which, as a minimum, contains: the throughput, source of waste oil (contaminated fuel); date and volume (weight) of waste oil sent to outside disposers, and the hauler. The log shall be maintained on-site for at least 2 years and presented to District personnel upon request.

NOTE: This ATC is to remove one 5,000 gallon tank leaving three 5,000 gallon storage tanks remaining.

Fee Schedule: 5 (b)

Rating: 15000 gallons

SIC: 9711

SCC: 9999999

Location/UTM(Km):
529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

<p>NTC - Public Works Attn: Air Resources Manager Fort Irwin, CA 92310</p>

By: **COPY**
Eldon Heaston
 Air Pollution Control Officer