



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

T003020

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: FEBRUARY 2026**

#### **OWNER OF OPERATOR (Co.#508)**

Union Pacific Railroad Co  
2015 S Willow St. Manager of Env Field Ops  
Bloomington, CA 92316

#### **EQUIPMENT LOCATION (Fac.#1179)**

UPRR Yermo Yard  
1 Union Pacific Blvd  
Yermo, CA 92398

#### **Description:**

WASTE OIL STORAGE TANK (TNKO-0179) consisting of: A 10,000 gallon capacity vertical tank measuring approximately 8.75 feet in diameter x 22 feet in length.

#### **CONDITIONS:**

1. This tank shall be operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rules 204 and 1303]

2. Only waste oil generated by UPRR Co. at their Yermo Rail Yard shall be stored in this tank.

[District Rule 204]

3. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.

[District Rule 463(C)(3)]

4. All waste oil stored in the tank shall have a Reid Vapor Pressure (RVP) of less than 1.55 pounds per square inch (80 mm Hg). The RVP shall be measured and recorded annually.

Fee Schedule: 5 (b)

Rating: 15000 gallons

SIC: 4013

SCC: 39090001

Location/UTM(Km): 518E/3863N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Union Pacific Railroad Co  
2401 E. Sepulveda Blvd.

Long Beach, CA 90810

By: **COPY**

**Brad Poiriez**

Air Pollution Control Officer

[District Rules 1302 and 1320]

5. The owner/operator (o/o) shall maintain on-site a log for this tank which, as a minimum, contains the following for each day of use:

- a. Record of liquids stored in this tank, verified by MSDS and by retention of the waste manifests issued upon disposal of waste oil.
- b. Date of use;
- c. Source and amount of waste oil placed into the tank;
- d. Destination and amount of oil sent out for disposal/re-refining; and
- e. Results of annual Reid Vapor Pressure readings as required in Condition 4.

This log shall be retained on-site for a minimum of two (2) years and provided to District personnel on request.

[District Rule 463(D)(1), 463(D)(3)]

6. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]