



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T003237

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co. #86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac. #3245)

USMC AGCC - USN Naval Hospital
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278

Description:

TANKS (BLDG 1145, BASE HOSPITAL) consisting of: (2) 20,000 gallon above ground double wall steel diesel fuel tanks, equipped with submerged fill tubes, overflow protection, and vent valves.

CONDITIONS:

1. These tanks shall be operated and maintained in strict accord with the manufacturer/supplier recommendations.
2. No diesel fuel, whose sulfur concentrations exceeds 0.0015% on a weight per weight basis shall be placed into these tanks.
3. All delivery receipts and their attendant sulfur analytical certification shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.

Fee Schedule: 5 (b)

Rating: 40000 gallons

SIC: 9711

SCC: 99999999

Location/UTM(Km):
587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Eldon Heaston
Air Pollution Control Officer