



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T004250

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2009

OWNER OF OPERATOR (Co. #31)

Southern California Gas Co. - MD
9400 Oakdale Avenue
Chatsworth, CA 91313

EQUIPMENT LOCATION (Fac. #1437)

SCG - Blythe
13100 W 14th Avenue
Blythe, CA 92225

Description:

NATURAL GAS ODORANT STORAGE AND INJECTION SYSTEM consisting of: YZ Model 8200GE-00N-A1-2 pneumatically driven odorant injection pump, and two odorant storage tanks at Plant #1. The odorant storage tanks are pressurized with a natural gas blanket and are kept at ambient temperature.

EQUIPMENT

Capacity	Equipment Description
2000	Odorant storage tank, 3 ft 4 in diameter by 29 ft 6 in high (Captan 50 blend)
50	Odorant storage tank, 18 in diameter by 4 ft high (Captan 50 blend)

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be properly maintained and kept in good operating condition at all times.
3. This tank and the delivery truck used to fill this tank must be equipped with a Two Point Phase I type vapor recovery system.
4. A Two Point Phase I type vapor recovery system must be utilized whenever this tank is being filled.

Fee Schedule: 5 (a) Rating: 2050 gallons SIC: 4922 SCC: 30600811 Location/UTM(Km): 719E/3271N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Gas Co. - MD
PO Box 2300, SC 9314
Chatsworth, CA 91313-2300

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

5.This tank shall not be filled to greater than 90% of its maximum capacity (to allow for expansion within tank).