MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

T005361

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA 923105085

Description:
TANK #5 (NEAR BLDG 630) consisting of: one 5,000 gallon Bryant Tank System w/containment - located about 700 feet from facility 630.

CONDITIONS:

1. Only internal combustion engine crankcase drainage oil, spent radiator fluid or contaminated fuel may be stored in this tank.

2. The owner/operator (o/o) shall notify the District, in writing, thirty days prior to making any change in the material stored in this tank. Compliance with District Rules shall be assured by obtaining a modified permit for the proposed material prior to change of product to be stored in this tank.

3. Used crankcase oil, contaminated fuel or spent radiator fluid shall not be stored in the same tank at the same time.

4. The o/o shall maintain an operators log for this tank which, as a minimum, contains: the throughput, source of stored material; date and volume (weight) of waste oil sent to outside disposers, and the hauler. The log shall be maintained on-site for at least 2 years and presented to District personnel upon request.

Fee Schedule: 5 (a)	Rating: 5000 gallons	SIC: 9711	SCC: 99999999	Location/UTM(Km): 529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL