



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T008218

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JULY 2026

OWNER OF OPERATOR (Co. #352)

Pilot Travel Centers, LLC
5508 Lonas Rd.
Knoxville, TN 37909

EQUIPMENT LOCATION (Fac. #2427)

Pilot Travel Center #200
5725 Hwy 58
Kramer Junction, CA 93516

Description:

TANKS consisting of: Three 20,000-gallon underground tanks for diesel fuel and one 20,000 gallon Bio-Diesel tank for a total of 80,000 gallons, (see G008215 for Gasoline Dispensing Facility PTO)

EQUIPMENT

Capacity	Equipment Description
20	Diesel fuel (20,000 gallons)
20	Diesel fuel (20,000 gallons)
20	Diesel fuel (20,000 gallons)
20	Bio-Diesel fuel (20,000 gallons)

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 1302]

Fee Schedule: 5 (b)

Rating: 60000 gallons

SIC: 5541

SCC: 40100251

Location/UTM(Km):
450E/3875N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pilot Travel Centers, LLC
5508 Lonas Drive

Knoxville, TN 37909

By: **COPY**
Brad Poiriez
Executive Director

2. These tanks shall only be used to store Ultra Low Sulfur Diesel (ULSD) and Biodiesel Fuels.
[District Rules 463 and 1320]

3. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.
[District Rule 463(C)(3)]

4. The owner/operator shall maintain a log of all inspections, repairs, and maintenance on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
[District Rule 463]

5. The owner/operator shall keep a monthly summary of the throughput for the calendar year to date. This log shall be kept on site and available to District personnel upon request.
[District Rule 462]

6. The annual combined throughput of diesel and biodiesel fuel shall not exceed 15,000,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.
[District Rule 1320]