MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T009632

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2006

OWNER OF OPERATOR (Co.#3254)

5E SVM Operations, LLC
13200 Main Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#2)

SVM - Trona Plant
13200 Main Street
Trona, CA 93562

Description:
TANK, BRINE (LLX) consisting of: Hydrocarbon emissions, mainly kerosene outgassing from the brine is vented to a vapor recovery system (B001916) and burned within the Boilers 25 & 26 (B000555, and B000554).

CONDITIONS:

1. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

2. The owner/operator, o/o, shall install, operate and maintain this tank and ancillary piping, valving, electrical and instrumentation consistent with those requirements to be compliant with District Rules 462 and 463.

3. This equipment shall be operated in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

4. All gauge hatches, roof supports, manholes, automatic bleeder vents, rim vents, gauge wells, etc., shall be equipped with vapor-tight seals or breather vents set at no less than 10% of the maximum allowable working pressure of the roof.

5. This tank shall only be used for the storage of effluent Brine liquid.

Fee Schedule: 5 (a)	Rating: 1000 gallons	SIC: 1474	SCC: 49000599	Location/UTM(Km): 466E/3957N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

5E SVM Operations, LLC
P.O. Box 367
Trona, CA 93592-0367

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

6. NMHC emitted to the atmosphere from this equipment, when added to the NMHC emissions from Boiler No. 25 (B000555) and Boiler No. 26 (B000554), shall not exceed 773.6 pounds per day.