



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T010027

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2009

OWNER OF OPERATOR (Co.#15)

Pacific Gas & Electric/Air Permits
PO Box 28150
Oakland, CA 94604-8150

EQUIPMENT LOCATION (Fac.#2998)

PG&E - IM3 Remediation Site
I-40 and Park Moabi Rd/5 miles E of
Needles, CA 92363

Description:

TANK, STORAGE consisting of: 3000 gallon Supervault protected aboveground storage tank equipped with phase I vapor recovery system per Executive Order G-70-132-B; Phase II is not required. Pressure Vacuum (PV) valve shall be part number 749CRB; pressure setting 3" w.c. and vacuum is 8" w.c.

EQUIPMENT

Capacity	Equipment Description
3000	Denatured Ethanol Storage Tank

CONDITIONS:

1. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment. Such logs or records shall be maintained at the facility for at least five (5) years and available to the District upon request.

Additionally, a daily log containing the following minimum information is required:

- a) Tank input
- b) Tank output
- c) Average stored volume over the 24 hour period (midnight to midnight)
- d) Storage and transfer temperatures of the organic liquid
- e) A monthly summary of the throughput for the calendar year to dated.

Fee Schedule: 5 (a)

Rating: 3000 gallons

SIC: 4939

SCC: 40200910

Location/UTM(Km):
718E/3858N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits PO Box 28150 Oakland, CA 94604-8150
--

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

2. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District.

3. The o/o shall perform the following tests within 60 days of construction completion and annually thereafter in accord with the following test procedures:

a. Static Pressure Decay Test per CARB test method TP-201.3B (2-inch test)

b. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

The District shall receive passing test reports no later than six (6) weeks prior to the expiration date of this permit.

4. The o/o shall install, maintain, and operate this equipment in compliance with CARB Executive Order G-70-132-B, with the exception of the Phase II system, which is not required.

5. This storage system shall only be used for non-fuel storage of de-natured ethanol; the fueling of any contrivance from this tank is prohibited.

6. All tank loading and unloading shall occur utilizing properly functioning integral Phase I system.